



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx IMQ 18.0009X

Issue No: 0

Certificate history:

[Issue No. 0 \(2018-10-24\)](#)

Status: **Current**

Page 1 of 3

Date of Issue: **2018-10-24**

Applicant: **PROSENSE TEKNOLOJI SAN. LTD. STI**  
YUKARI MAH. HARMAN SOK. 42  
TR- KARTAL ISTANBUL  
**Turkey**

Equipment: **Gas detector**

Optional accessory: *P\*\*\*\* and P\*\*\*PE Series*

Type of Protection: **Ex db**

Marking:  
Ex db IIC T4 Gb; Ex db IIC T5 Gb

Approved for issue on behalf of the IECEx  
Certification Body:

Mr. Mauro CASARI

Position:

IMQ ExCB Manager

Signature:  
(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](#).

Certificate issued by:

**Istituto Italiano del Marchio di Qualità S.p.A**  
Via Quintiliano 43  
20138 Milano  
Italy





# IECEx Certificate of Conformity

Certificate No: IECEx IMQ 18.0009X

Issue No: 0

Date of Issue: 2018-10-24

Page 2 of 3

Manufacturer: PROSENSE TEKNOLOJI SAN. LTD. STI  
YUKARI MAH. HARMAN SOK. 42  
TR- KARTAL ISTANBUL  
Turkey

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

## STANDARDS:

The apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

**IEC 60079-0 : 2011** Explosive atmospheres - Part 0: General requirements  
Edition:6.0

**IEC 60079-1 : 2014-06** Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"  
Edition:7.0

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

## TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

Test Report:

[IT/IMQ/ExTR18.0009/00](#)

Quality Assessment Report:

[GB/EXV/QAR18.0006/00](#)



# IECEx Certificate of Conformity

Certificate No: IECEx IMQ 18.0009X

Issue No: 0

Date of Issue: 2018-10-24

Page 3 of 3

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

**P\*\*\*\* and P\*\*\*\*PE Series** gas detectors are equipment designed to detect toxic compounds in industrial environments and classified areas.

They are composed by:

- a gas sensor, contained in a metallic flameproof enclosure and protected by a sinter metal element,
- a metallic flameproof junction box, containing terminals for electric connections and electronic circuits for amplification / conversion / transmission of signals.

The metallic flameproof junction box has up to three threaded openings for cable entry, and one threaded opening on bottom side where the gas sensor metallic flameproof enclosure is fastened.

Installation and maintenance of gas detectors shall be performed according to IEC 60079-14 and IEC 60079-17, and strictly in compliance with details listed in manufacturer's use and safety instructions.

**P\*\*\*\* and P\*\*\*\*PE Series** gas detectors model coding system:

P – (XY) (W) (Z) (PE)

More details in Annex.

### SPECIFIC CONDITIONS OF USE: YES as shown below:

**P\*\*\*\* and P\*\*\*\*PE Series** gas detectors must be installed only with sensor head pointing downwards.

Cable glands and thread adapters used for entry into the enclosure, as well as blanking elements, shall be certified as Ex Components according to protection "d", and suitable for the ambient temperature range specified above.

Electrical components/devices installed inside the junction box must not exceed a total power consumption of 2,5 W in order to ensure compliance with the declared maximum temperature rise.

Sinter disc and sensor head cap is considered a mounting component and must be replaced as a single unit.

### Annex:

[PROSENSE-IECEx\\_IMQ 18.0009X-Annex-Issue 0.pdf](#)

**Annex to:** IECEx IMQ 18.0009 X issue No. 0  
**Applicant:** PROSENSE TEKNOLOJI SAN. LTD. STI  
**Description:** Gas detector  
**Series:** Series P\*\*\*\* and P\*\*\*PE



## General description

**P\*\*\*\* and P\*\*\*PE Series** gas detectors are equipment designed to detect toxic compounds in industrial environments and classified areas.

They are composed by:

- a gas sensor, contained in a metallic flameproof enclosure and protected by a sinter metal element,
- a metallic flameproof junction box, containing terminals for electric connections and electronic circuits for amplification / conversion / transmission of signals.

The metallic flameproof junction box has up to three threaded openings for cable entry, and one threaded opening on bottom side where the gas sensor metallic flameproof enclosure is fastened.

Installation and maintenance of gas detectors shall be performed according to IEC 60079-14 and IEC 60079-17, and strictly in compliance with details listed in manufacturer's use and safety instructions.

## Design options

**P\*\*\*\* and P\*\*\*PE Series** gas detectors model coding system:

**P – (XY) (W) (Z) (PE)**

(XY) Gas Type			
30. LPG	42. Etanol	54. Dioxane	66. Sulfur dioxide
31. Methane	43. Iso propanol	55. Ethane	67. Nitric oxide
32. Petrol vapour	44. Carbon monoxide	56. Butyl alcohol	68. Nitrogen dioxide
33. n Butane	45. Acetone	57. Stylen	69. Chlorine
34. Propane	46. Methyl ethy keton	58. Propylene	70. Hydrocarbon
35. Hexane	47. Ethyl acetate	59. Xylene	71. Carbondioxide
36. Hydrogen	48. Ammonia	60. Acetylene	72. Freon Gas
37. Pentane	49. Ethylene	61. Benzene	73. JP8
38. Toulon	50. Acetic acid	62. Ethylene oxide	74. Formaldehyde
39. Methanol	51. Butyl acetat	63. Vinyl acetat (VAM)	75. HCN
40. Heptane	52. Cyclo hexane	64. Hydrogen sulfide	76. Hydrogen peroxide
41. Octane	53. Cyclo pentane	65. Oxygen	77. Nonane

(W) Sensor Head
1. SH10
2. SH20
3. SH30

(Z) Sensor Type
1. Semiconductor
2. Catalytic
3. Infrared
4. Electrochemical
5. Pellistor

Final PE code applies only to gas detectors with SH10 sensor head.

IP code: 65 (IEC 60529)

### Rated characteristics

$V_{in}$ : 12 -24 V<sub>dc</sub> ; P<sub>max</sub>: 2,5 W

Ambient temperature: -20 °C ÷ +40 °C ; -20 °C ÷ +50 °C; -20 °C ÷ +70 °C

**Annex to:** IECEx IMQ 18.0009 X issue No. 0  
**Applicant:** PROSENSE TEKNOLOJI SAN. LTD. STI  
**Description:** Gas detector  
**Series:** Series P\*\*\*\* and P\*\*\*PE

---



### Schedule of limitations

P\*\*\*\* and P\*\*\*PE Series gas detectors must be installed only with sensor head pointing downwards.

Cable glands and thread adapters used for entry into the enclosure, as well as blanking elements, shall be certified as Ex Components according to protection “d”, and suitable for the ambient temperature range specified above.

Electrical components/devices installed inside the junction box must not exceed a total power consumption of 2,5 W in order to ensure compliance with the declared maximum temperature rise.

Sinter disc and sensor head cap is considered a mounting component and must be replaced as a single unit.

### Markings

Ex db IIC T4 Gb ; Ex db IIC T5 Gb

### Manufacturer's instructions

Title:	Drawing No.:	Rev. Level:	Date:
Prosense P Series gas Detector Installation and User Manual	PRS-UM-P-EN	01	08.2018
Prosense PE Series gas Detector Installation and User Manual	PRS-UM-PE-EN	01	08.2018
Safety Instruction for hazardous area	PRS-SI-EN	01	08.2018