



# Certificate of Compliance

## FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment: **RFD 2FTN Flame Detector**

Equipment Model Designations: **RFD-2FTN**

Approval Guide Listing Category: 3260

Electrical Signaling Alarm Signal Initiating Devices Fire Detection, Flame-Actuated

Rezontech Co Ltd  
72-9, Beolmal-ro, Dongan-gu  
Anyang-si, Gyeonggi-do 14058  
Korea, Republic of

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standards and other documents:

<i>Approval Standards</i>		<i>Other Standards</i>	
<i>Class Number</i>	<i>Date</i>	<i>Organization, Designation</i>	<i>Date</i>
3260	2018		

Original Approval Job Identification: PR454251

Approval Granted: 22 September 2020

Related Report:

Subsequent Revisions:

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Insert listing page text here, or on next page.

  
J.E. Marquedant  
VP, Manager - Electrical Systems  
FM Approvals  
1151 Boston-Providence Turnpike,  
Norwood MA, 02062 USA

22 September 2020

Date



Member of the FM Global Group



# Certificate of Compliance

## **RFD-2FTN**

Rezontech RFD-2FTN, UV/IR flame detector (Firmware Ver. 2.0) The detector enclosure is suitable for indoor/outdoor for use over ambient operating temperature range of -40°C (-40°F) to 65°C (149°C). Proper installation requires the use of a mounting bracket assembly. Detectors operate from 17 to 30 V dc. Communicate alarm and trouble conditions by relay contacts and 4-20 mA signals. Fuel tested for response include the following: Heptane



*Member of the FM Global Group*