



EXPLOSION PROTECTION

CERTIFICATE OF CONFORMITY

Cert NO.GYJ13.1035X

This is to certify that the product

IR3 Type Flame Detector

manufactured by **REZONTECH Co.,Ltd.**
(Address:805, MEGA-VALLEY,
KWANYANG-DONG,DONGAN-GU,ANYANG-SI, GYENGGI-DO,SOUTH

which model is **RFD-3000X**

Ex marking **Ex d II C T5 Gb DIP A21 T_A,T5 IP67**

product standard /

drawing number **Ex-3000X-000-01**

has been inspected and certified by NEPSI, and that it conforms
to **GB 3836.1-2010/GB 3836.2-2010/GB 12476.1-2000**

This Approval shall remain in force until **2018.02.20**

Remarks 1.Conditions for safe use are specified in the attachment to this certificate.
2.Symbol "X" placed after the certification number denotes specific conditions of use,
which are specified in the attachment to this certificate.

Director

**National Supervision and Inspection Centre for
Explosion Protection and Safety of Instrumentation**

Issued Date **2013.02.21**



This Certificate is valid for products compatible with the documents and samples approved by NEPSI.