



# Certificate of Compliance

## FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment:

RFD-3000X

Rezontech RFD-3000X, Triple IR flame detector (Firmware Ver. 1.0) Detectors are suitable indoor/outdoor for use over ambient operating temperature range of -40°F (-40°C) to 176°F (75°C). Proper installation requires the use of a mounting bracket assembly. Detectors operate from 18 to 30 V dc. Communicate alarm and trouble conditions by relay contacts and 4-20 mA signals. Fuel tested for response include the following: Heptane

*Approval Guide Listing: Category:*

Electrical Signaling, Signaling Systems (Fire), Alarm Signal Initiating Devices, Fire Detection, Flame Actuated

Rezontech Co Ltd  
805 Megavalley  
Gwanyang-dong  
Dongan-gu Anyang-si  
Kyonggi-do, Gyeonggido [Kyonggi-do] 431-060  
Korea, Republic of

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standards and other documents:

<i>Approval Standards</i>	<i>Date</i>	<i>Other Standards</i>	<i>Date</i>
<i>Class Number</i>		<i>Organization, Designation</i>	
3260	2000	ANSI/ NFPA 72	2002
		ANSI/3260	2004

Original Approval Job Identification: 0003043770

Approval Granted: 8 May, 2012

Related Report: 0003037260

Subsequent Revisions: None



*Member of the FM Global Group*

A handwritten signature in dark ink, appearing to read 'D. Waite', written over a horizontal line.

David Waite  
Technical Team Manager  
FM Approvals  
1151 Boston-Providence Turnpike,  
Norwood MA, 02062 USA