

# Orbis I.S. Optical Smoke Detector



## Technical data

All data is supplied subject to change without notice. Specifications are typical at 24 V, 23°C and 50% RH unless otherwise stated.

<b>Detection principle</b>	Photo-electric detection of light scattered by smoke particles over a wide range of angles.
<b>Sampling frequency</b>	Once every four seconds
<b>Operating voltage</b>	14.8 V dc to 28 V dc
<b>Supply Wiring</b>	Two wire supply, polarity sensitive
<b>Polarity reversal</b>	Not allowed
<b>Power up time</b>	< 20 seconds
<b>Minimum 'detector active' voltage</b>	12 V
<b>Power-up surge current at 24 V</b>	105 µA
<b>Average quiescent current at 24 V</b>	85 µA
<b>Alarm load</b>	325 Ω in series with a 1.0 V drop
<b>Minimum holding voltage</b>	5 V
<b>Minimum voltage to light alarm LED</b>	6 V
<b>Alarm reset voltage</b>	< 1 V
<b>Alarm reset time</b>	One second
<b>Alarm indicator</b>	Integral indicator with 360° visibility
<b>Remote output LED (-) characteristic</b>	4.7 kΩ connected to negative supply
<b>Operating and storage temperature</b>	-40°C to +70°C Operating temperature is restricted by the intrinsic safety gas classification. Class T5: -40°C to +45°C Class T4: -40°C to +60°C The detector must be protected from conditions of condensation or icing
<b>Humidity (no condensation or icing)</b>	0% to 98% RH
<b>Effect of atmospheric pressure on optical sensor</b>	Unaffected by wind
<b>Effect of wind speed</b>	Insensitive to pressure
<b>Designed to IP Rating</b>	IP23D
<b>Standards &amp; approvals</b>	EN54-7, CPD, LPCB, MED, LR, DNV-GL, BV, ABS, CCS, KRS, VdS, BOSEC, IECEX, ATEX, PESO and FG
<b>BASEEFA Cert No.</b>	BASEEFA06ATEX0007X
<b>Dimensions</b>	100 mm diameter x 42 mm height 100 mm diameter x 50 mm height in base
<b>Weight</b>	75 g detector 135 g detector with base
<b>Materials</b>	Housing: White flame-retardant polycarbonate Terminals: Nickel plated stainless steel

## Product overview

<b>Product</b>	I.S. Optical Smoke Detector
<b>Part No.</b>	ORB-OP-52027-APO
<b>Product</b>	I.S. Optical Smoke Detector with flashing LED
<b>Part No.</b>	ORB-OP-52028-APO

## Approvals



## Product information

The sensing technology in the Orbis I.S. Optical Smoke Detector is significantly different in design from previous optical smoke detectors.

- Improved sensitivity to black smoke
- Compensation for slow changes in sensitivity
- Extra confirmation of smoke before an alarm signal is given

## Features

Optical smoke detectors have always been recognised as good detectors for general use. They are regarded as particularly suitable for smouldering fires and escape routes.

The performance of Orbis Marine optical detectors is good in black as well as in white smoke. In this respect Orbis detectors are different from traditional optical smoke detectors which perform far better in white smoke than in black.

Orbis I.S. Optical Smoke Detectors are also designed to reduce significantly the incidence of false alarms through over-sensitivity to transient phenomena.

Orbis I.S. Optical Smoke Detectors are recommended for use as general purpose smoke detectors for early warning of fires in most areas.

## Operation

Orbis I.S. Optical Smoke Detectors work on the well established light scatter principle. The remarkable optical design of the Orbis I.S. Optical Smoke Detector enables it to respond to a wide spectrum of fires.

The sensing chamber contains an optical sensor which measures back-scattered light as well as the more usual forward-scattered light. Sensitivity to black smoke is greatly improved.

The detector is calibrated so that Orbis is highly reliable in detecting fires, but is much less likely to generate false alarms.

The stability of the detector-high reliability, low false alarm rate is further increased by the use of algorithms to decide when the detector should change to the alarm state. This removes the likelihood of a detector producing an alarm as a result of smoke from smoking materials or from another non-fire source.

## Classification

Ex ia IIC T5 -40°C<Ta <+45°C (T4<60°C)Ga

## EMC Directive 2014/30/EU

The Orbis I.S. Optical Smoke Detector complies with the essential requirements of the EMC Directive 2014/30/EU, provided that it is used as described in this datasheet.

A copy of the Declaration of Conformity is available from the Apollo website: [www.apollo-fire.co.uk](http://www.apollo-fire.co.uk)

Conformity of the Orbis I.S. Optical Smoke Detector with the EMC Directive, does not confer compliance with the directive on any apparatus or systems connected to them.

## Construction Products Regulation 305/2011/EU

The Orbis I.S. Optical Smoke Detector complies with the essential requirements of the Construction Products Regulation 305/2011/EU.

A copy of the Declaration of Performance is available from the Apollo website: [www.apollo-fire.co.uk](http://www.apollo-fire.co.uk).


## Marine Equipment Directive 2014/90/EU

The Orbis I.S. Optical Smoke Detector complies with the essential requirements of the Marine Equipment Directive 2014/90/EU.

## ATEX Directive 2014/34/EU

The Orbis I.S. Optical Smoke Detector complies with the essential requirements of the ATEX Directive 2014/34/EU.

### Orbis I.S. Optical Smoke Detector dimensional drawing



**Orbis detectors: LED status**

Feature	Description	Red LED status	Yellow LED status
StartUp™	Confirms that the detectors are wired in the correct polarity	Flashes once per second	No Flash
FasTest™	Maintenance procedure, takes just four seconds to functionally test and confirm detectors are functioning correctly	Flashes once per second	No flash
DirtAlert™	Shows that the drift compensation limit has been reached	No flash	Flashes once per second in StartUp (Stops flashing when StartUp finishes)
SensAlert™	Indicates that the sensor is not operating correctly	No flash	Flashes every four seconds (Flashes once per second in StartUp)
Normal operation	At the end of StartUp and FasTest (without flashing LED as standard)	No flash	No flash
Flashing LED version	Detectors red LED flashes in normal operation (at the end of FasTest)	Flashes every four seconds	No flash

This page has intentionally been left blank